

Form V-2: Mitigation Measures - Range of Changes in Damage

Modeling Organization: AIR Worldwide
Model Name & Version Number: AIR Hurricane Model for the U.S. v16.0.0 as implemented in Touchstone v4.1.0
Model Release Date: #####

INDIVIDUAL MITIGATION MEASURES		PERCENTAGE CHANGES IN DAMAGE ((REFERENCE DAMAGE RATE - MITIGATED DAMAGE RATE) / REFERENCE DAMAGE RATE) * 100										
		FRAME BUILDING					MASONRY BUILDING					
		WINDSPEED (MPH)					WINDSPEED (MPH)					
		60	85	110	135	160	60	85	110	135	160	
	REFERENCE BUILDING	-	-	-	-	-	-	-	-	-	-	
ROOF CONFIG URATIO N	BRACED GABLE ENDS	10.1	13.6	13.2	9.9	6.3	9.7	13.5	13.2	9.8	6.1	
	HIP ROOF	14.0	17.5	16.7	12.8	9.0	13.4	17.2	16.5	13.1	8.8	
ROOF COVERING	METAL	-4.5	-2.6	-1.2	-0.5	-0.5	-4.3	-2.5	-1.1	-0.5	-0.5	
	ASTM D7158 CLASS F SHINGLES (150 MPH)	0.6	0.5	0.3	0.1	0.1	0.6	0.5	0.3	0.2	0.1	
	MEMBRANE	0.0	7.6	8.2	0.0	0.0	0.0	8.1	8.4	0.0	0.0	
	NAILING OF DECK	8d	12.8	22.8	24.2	17.8	10.2	12.3	22.2	23.7	18.1	10.0
ROOF- WALL STRENG TH	CLIPS	1.7	5.1	10.7	11.6	7.6	1.7	5.4	10.8	11.8	7.4	
	STRAPS	2.2	6.5	13.1	14.1	9.8	2.2	6.7	13.2	14.5	9.6	
WALL- FLOOR STRENG TH	TIES OR CLIPS	0.0	0.4	0.6	2.6	7.0	0.0	0.4	0.5	2.6	6.8	
	STRAPS	0.0	0.8	2.2	6.1	12.7	0.0	0.9	2.1	6.1	12.3	
WALL- FOUNDATION STRENGTH	LARGER ANCHORS OR CLOSER SPACING	0.0	0.4	0.6	2.6	7.0	-	-	-	-	-	
	STRAPS	0.0	0.8	2.2	6.1	12.7	-	-	-	-	-	
	VERTICAL REINFORCING	-	-	-	-	-	0.0	1.1	2.2	6.9	15.0	
OPENING PROTECTION	WINDOW SHUTTERS	STRUCTURAL WOOD PANEL	9.4	13.2	12.5	10.0	8.2	8.8	12.9	12.2	9.7	7.9
		METAL	9.4	13.2	12.5	10.0	8.2	8.8	12.9	12.2	9.7	7.9
	DOOR AND SKYLIGHT COVERS		1.7	3.7	5.2	5.0	4.4	1.5	4.0	4.9	4.9	4.3
WINDOW, DOOR, SKYLIGHT STRENGTH	WINDOWS	IMPACT RATED	13.6	19.8	19.3	16.1	13.9	12.7	18.9	18.6	16.1	13.5
	ENTRY DOORS	MEETS WINDBORNE DEBRIS REQUIREMENTS	1.7	3.7	5.2	5.0	4.4	1.5	4.0	4.9	4.9	4.3
	GARAGE DOORS	MEETS WINDBORNE DEBRIS REQUIREMENTS	2.6	4.0	3.7	2.1	1.4	2.8	4.7	3.9	2.3	1.4
	SLIDING GLASS DOORS	MEETS WINDBORNE DEBRIS REQUIREMENTS	-0.3	-0.6	-0.8	-0.7	-0.6	-0.3	-0.7	-0.8	-0.7	-0.6
	SKYLIGHT	IMPACT RATED	1.7	1.8	1.6	1.0	0.6	1.5	2.0	1.5	1.0	0.6
MITIGATION MEASURES IN COMBINATION		PERCENTAGE CHANGES IN DAMAGE ((REFERENCE DAMAGE RATE - MITIGATED DAMAGE RATE) / REFERENCE DAMAGE RATE)*100										
		FRAME BUILDING					MASONRY BUILDING					
		WINDSPEED (MPH)					WINDSPEED (MPH)					
		60	85	110	135	160	60	85	110	135	160	
BUIL DING	MITIGATED BUILDING	26.1	45.0	50.5	41.5	26.5	24.7	42.9	48.4	40.6	26.1	